



Jim Doyle, Governor
Mary P. Burke, Secretary

March 29, 2006

RECTORSEAL CORP.
CHARLES TOMPKINS
2601 SPENDWICK DR.
HOUSTON TX 77055

Re: Description: SOLVENT CEMENT
Manufacturer: RECTORSEAL CORP.
Product Name: RECTORSEAL ARTIC 616
Model Number(s): 55231, 55233, 55235, 55237 and 55239
Product File No: 20060074

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (14)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be used on PVC gravity flow DWV pipe without primer.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov